

**CERTIFICATE OF APPROVAL  
No CS 5017**

This is to certify that, in accordance with  
STS200 General Requirements for Certification of Enhanced Security Products  
The undermentioned products of

**GARADOR LIMITED**

**Bunford Lane, Yeovil, Somerset, BA2 2EJ  
Tel: 01935 443 700 Fax: 01935 443 757**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:


**CERTIFIED PRODUCT**  
**Guardian Range Garage Doorset**

**TECHNICAL SCHEDULE**  
**STS202 - Requirements for  
burglary resistance of  
construction products**

CLASSIFICATION			
Security	Weather	Strength	Material Specific
<b>STS202 BR1</b>	<b>NPD</b>	<b>NPD</b>	<b>NPD</b>

**NPD = No performance determined**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as  
Warrington Certification**



**Sir Ken Knight  
Chairman  
Impartiality Committee**



**Paul Duggan  
Certification Manager**

Issued: 12<sup>th</sup> March 2012  
Reissued: 3<sup>rd</sup> March 2017  
Next audit test due: 3<sup>rd</sup> March 2018  
Frequency: Annually  
Valid to: 2<sup>nd</sup> March 2022



---

## CERTIFICATE No CS 5017

### GARADOR LIMITED

---

#### Garador Limited – Guardian Range Garage Doorsets

1. This approval relates to the use of the above in providing a burglar resistance to STS 202: Issue 7: April 2016 level BR1.
2. The garage doorsets are approved on the basis of:
  - i. Initial type testing against STS202. Exova Willenhall test reports WIL314223, WIL314224, WIL338556 & WIL 377857.
  - ii. Audit testing at the frequency specified in STS 200 & STS 202 where relevant.
  - iii. A design appraisal against STS202 where relevant.
  - iv. Inspection and surveillance of factory production control at Bunford Lane, Yeocil, Somerset, BA20 2EJ.
3. This approval is applicable to complete garage doorsets only.
4. This certification is designed to demonstrate compliance of the garage doorset specifically with STS202 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
5. This approval is applicable to canopy & retractable, single-leaf garage doorsets in the Horizon, Carlton & Salisbury (glazed) design at leaf dimensions up to those given in Table 1.
6. Approved hardware items are:
  - Marques 5126 lock body
  - Yale AS301BN anti-snap or ISEO F6 Extra S single key cylinder
  - Canopy & retractable hardware

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

**CERTIFICATE No CS 5017  
GARADOR LIMITED**

**Garador Limited – Guardian Range Garage Doorsets**

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)
'Horizon' leaf garage door	2262	2115
'Carlton' leaf garage door	2722	2115
'Salisbury' glazed leaf garage door	2423	2115
Canopy door gear	2262	2115
Retractable door gear	2722	2115

**Table 1. Permitted Door Leaf Dimensions**

**Note:** Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

7. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
8. Labels to the EWCL design referencing CERTISECURE, STS202 BR1, Garador Limited, and CERTISECURE certificate No. CS 5017 shall be affixed to each garage doorset in the prescribed position.
9. This approval relates to on-going production. The garage doorset and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

**Further Information**

Further information regarding the details contained in this certificate may be obtained from Garador Limited Bunford Lane, Yeovil, Somerset. BA20 2EJ, Tel: 01935 443700, Fax: 01935 443757

Further information regarding CERTISECURE certification and other approved products can be obtained from Exova Warrington Certification, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).